

ADDENDUM NO. 2

Keller-Harris Community Center Improvement Project

December 23, 2022

This Addendum to the specifications is for the purpose of adding, clarifying, or deleting certain information to the Drawings and Specifications described above and shall be made part thereof, and subject to all applicable requirements hereunder as if originally shown and/or specified.

1. **BID DATE:** The bid date remains the same: **Thursday, December 29, 2022 at 2:00PM**

2. **MANDATORY PRE-BID WALK-THROUGH ATTENDEES:**

Eliza Carbajal – Pinhero Construction	Juan Lopez – Leonida Builders Inc.
Kyle Simpson – Linden Construction	Gregg Worthington – Valley-Wide Recreation
Joe Walsh – Valley-Wide Recreation	James Edwards – Valley-Wide Recreation
Justin Schweitzer – Valley-Wide Recreation	James Salvador – Valley-Wide Recreation

3. **SUBMITTED QUESTIONS AND ANSWERS:**

Q1. What do the panels in the shed service?

A1. The panels provide electricity to the fire suppression system.

Q2. Are the panels in the shed serving as protection from the elements?

A2. Currently, the panels are free standing in the shed and their location is not intended to protect them from the elements.

Q3. Will the panels need to be relocated?

A3. The panels will not need to be relocated. The panels are free standing and not attached to the shed.


Q4. A broken window was observed in one of the rooms. Will this need to be replaced?

A4. At this time, Valley-Wide Recreation and Park District is not proceeding with the replacement of the broken window.

Q5. Can access be granted for a subcontractor to inspect the condition of the existing pumps and system?

A5. Access will not be granted prior to the award of the project.

Sincerely,


Justin Schweitzer, Special Projects Supervisor
Valley-Wide Recreation and Park District