



NOTES:

1. PROVIDE 3" CLEARANCE BETWEEN VALVE & BOX
2. PROVIDE 3 EA. CONCRETE BRICKS UNDER VALVE BOX (TYP.)
3. SECURE END OF FLUSH LINE PIPING TO 4" DRAIN PIPE WITH PLUMBER'S TAPE

LD Consulting 2012 (Any deviation or reproduction of this design must be approved in writing by Valley-Wide Recreation & Park District)



VALLEY-WIDE RECREATION & PARK DISTRICT

FLUSH VALVE ASSEMBLY

IR-34

REV. 2012