



NOTES:

1. INSTALLATION MUST CONFORM TO LOCAL CODES
2. CONTRACTOR MUST PROVIDE BACKFLOW CERTIFICATION
3. LOCATE BACKFLOW IN PLANTER WHERE POSSIBLE
4. WRAP ALL PIPING WHERE CONCRETE OCCURS
5. WRAP ALL IRON PIPE IN CONTACT WITH SITE SOIL

LD Consulting 2012 (Any deviation or reproduction of this design must be approved in writing by Valley-Wide Recreation & Park District)



VALLEY-WIDE RECREATION & PARK DISTRICT

BACKFLOW DEVICE 2-1/2" & LARGER

IR-11

REV. 2012