



NOTES:

1. INSTALLATION MUST CONFORM TO LOCAL CODES
2. OBTAIN EMWD APPROVAL PRIOR TO INSTALLATION
3. LOCATE FILTER IN PLANTER WHERE POSSIBLE
4. WRAP ALL PIPING WHERE CONCRETE OCCURS
5. ALL EXPOSED PIPING FROM FILTER FLUSH LINE SHALL BE BRASS
6. CONTRACTOR MUST PROVIDE BACKFLOW CERTIFICATION PRIOR TO ACCEPTANCE
7. ALL BALL VALVES AND UNIONS MUST BE 4" MIN. ABOVE CONCRETE SLAB

LD Consulting 2012 (Any deviation or reproduction of this design must be approved in writing by Valley-Wide Recreation & Park District)



VALLEY-WIDE RECREATION & PARK DISTRICT

POTABLE WATER BACKFLOW/FILTER

IR-12B

REV. 2012