



NOTES:

1. CONTRACTOR SHALL PROVIDE 5 FOOT TEE WRENCH WITH 2" SQUARE NUT FOR BUTTERFLY VALVE OPERATION
2. PROVIDE 3 EA. CONCRETE BRICKS UNDER VALVE BOX (TYP.)

LD Consulting 2012 (Any deviation or reproduction of this design must be approved in writing by Valley-Wide Recreation & Park District)



VALLEY-WIDE RECREATION & PARK DISTRICT

RESTRAINED GATE VALVE 4" & OVER

IR-06

REV. 2012