



NOTES:

1. ROOT BARRIERS SHALL BE MANUFACTURED BY "DEEP ROOT" OR APPROVED EQUAL
2. ROOT BARRIERS MUST BE INSTALLED FOR ANY TREE WITHIN 8' OF ANY HARDSCAPE SURFACE OR DECOMPOSED GRANITE PATH
3. TOP OF ROOT BARRIERS MUST BE FLUSH WITH GRADE
4. PROVIDE 24" BELOW GRADE ROOT BARRIERS ADJACENT CURBS
5. PROVIDE 18" BELOW GRADE ROOT BARRIERS ADJACENT SIDEWALKS
6. PROVIDE BIO-BARRIER FOR TREES AS INDICATED IN SPECS.

LD Consulting 2012 (Any deviation or reproduction of this design must be approved in writing by Valley-Wide Recreation & Park District)



VALLEY-WIDE RECREATION & PARK DISTRICT

ROOT BARRIER

PL-08

REV. 2012