



NOTES:

1. ALL THREADED FITTINGS MUST HAVE 3/4" TEFLON TAPE
2. PROVIDE 2" CLEARANCE BETWEEN VALVE & BOX
3. PROVIDE 4 EA. CONCRETE BRICKS UNDER VALVE BOX (TYP.)
4. PROVIDE 4 EA. SCH 80 45 DEGREE ELLS TO ACHIEVE BALL VALVE HEIGHT PER DETAIL

LD Consulting 2012 (Any deviation or reproduction of this design must be approved in writing by Valley-Wide Recreation & Park District)



VALLEY-WIDE RECREATION & PARK DISTRICT

BRASS BALL VALVE 2" & SMALLER

IR-04

REV. 2012